

AA	SMITH JAY R. SMITH MFG. CO. MEMBER OF MORRIS GROUP INTERNATIONAL POST OFFICE BOX 3237 MONTGOMERY, ALABAMA 36109-0237 (USA) TEL: 334-277-8520 FAX: 888-377-7818 www.jrsmith.com			LOCATION
	SANI-CEPTOR® STAINLESS STEEL FLOOR, AREA & INDIRECT WASTE DRAINS WITH 12" (304) STAINLESS STEEL SQUARE TOPS			
	DRAWING NUMBER	S3001		
	SIZE	A		
SCALE:	NONE			
DATE:	5-4-82			
APPROVED BY:	JM			
CHECKED BY:	KH			
DRAWN BY:	CR			
FIGURE NUMBER	3001-Series			

WITH DOME BOTTOM STRAINER

USDA ACCEPTED

W/Dome Strainer	"B" DIM	Approx Wt. Lbs.	W/Sediment Bucket
3001	4(100)	14	3006
3002	6(150)	17	3007
3003	8(205)	20	3008
3004	10(255)	23	3009

Grates w/1/2" (13) holes - Free Area 34 SQ IN (219) SQ CM
 Optional Grates w/1/4" (6) holes - 18 SQ IN (116) SQ CM

A (Pipe Size) = 02(50), 03(75) or 04(100)
 Y NO-HUB Outlet

WITH SEDIMENT BUCKET

FEATURES, OPTIONS AND ORDERING INFORMATION

REGULARLY FURNISHED: 14 Gauge Type 304 SS Receptor Body with Seepage Control Holes, Cast Type 316 SS Ribbed Non-Tilt Loose Set ADA Grate with 1/2"(13) Square Holes. Perforated SS Dome Bottom Strainer or Sediment Bucket as indicated by Figure Number. Body Rim and Grate are polished to No. 4 finish.

VARIATIONS:

- ☐ BW Butt Weld Outlet (Specify Schedule -S05, -S10, or -S40)
- ☐ T Male Threaded Connection
- ☐ Less Seepage Control Holes -LSH
- ☐ Trap Primer Connection -P050 1/2"(13) & -P075 3/4"(19)
- ☐ With Anchor Flange -F
- ☐ With Flange and Flashing Clamp -F-C
- ☐ USDA Compliant

OPTIONAL MATERIALS:

- ☐ Drains: Fabricated from Type 316 Stainless Steel
- ☐ Funnel: Type 304 Stainless Steel
- ☐ Funnel: Type 316 Stainless Steel

Bucket Models Only:

- ☐ With SS Dome Bottom Strainer -DBS
- ☐ With SS Solid Bottom Ported Bucket -SBP
- ☐ With Mesh Lined Bucket -BS

NOTE:
 When determining location of this drain, consideration must be given to traffic loading factors. When used in areas where the drain is subjected to any traffic loading heavier than pedestrian foot traffic, the location, load and description of load shall be submitted to Jay R. Smith's Sales Engineering Department for evaluation and selection of proper grate.

OPTIONAL TOP GRATES AND COVERS

SUFFIX	DESCRIPTION	SUFFIX	DESCRIPTION
☐ -10	Less SS Grate	☐ -61	With SS Heel-Proof Ribbed Non-Tilt Loose Set Grate with 1/4" (6) SQ Holes.
☐ -12	With SS 1/2 Grate	☐ -63	With SS Medium Duty Heel-Proof Ribbed Non-Tilt Loose Set Grate with 1/4" (6) SQ Holes.
☐ -13	With SS 3/4 Grate	☐ -64	With SS Heavy Duty Ribbed Non-Tilt Loose Set ADA Grate with 1/2" (13) SQ Holes.
☐ -14	With SS 2 1/2" (64) SQ Center Hole Grate	☐ -66	With SS Extra Heavy Duty Ribbed Non-Tilt Loose Set ADA Grate with 1/2" (13) SQ Holes.
☐ -15	With SS Recessed Grate with Handle	☐ -68	With SS Extra Heavy Duty Ribbed Non-Tilt Loose Set 3/4 Grate with 1/2" (13) SQ Holes.
☐ -18	With NB Rim and Angle ADA Grate		
☐ -21	With SS Grate with 4" (100) DIA NB Funnel		
☐ -22	With SS Grate with 6" (150) DIA NB Funnel		
☐ -25	With SS Grate with 8 1/4(210) x 3 1/4(83) x 4 1/2"(115) High Oval NB Funnel		
☐ -26	With SS Grate with 6(150) x 2 1/2(64) x 1"(25) High Oval NB Funnel		
☐ -41	With SS Solid Cover		
☐ -42	With SS 1/2 Solid Cover		
☐ -43	With SS 3/4 Solid Cover		
☐ -44	With SS 2 1/2" (64) SQ Center Hole Solid Cover		

NOTE: Dimensions shown in parentheses are in millimeters.

• Flange is Located 2" (51) from Top of Drain 3" (76) When Specified

REV.	DATE	DESCRIPTION	BY	CKD. BY	WEIGHT POUNDS	VOLUME CUBIC FEET	FIGURE NUMBER 3001-Series
------	------	-------------	----	---------	---------------	-------------------	---



WARNING: Cancer and Reproductive Harm - www.P65Warnings.ca.gov