

F	JAY R. SMITH MFG. CO.® MEMBER OF MORRIS GROUP INTERNATIONAL POST OFFICE BOX 3237 MONTGOMERY, ALABAMA 36109-0237 (USA) TEL: 334-277-8520 FAX: 888-377-7818 www.jrsmith.com MEMBER OF: MEMBER OF: MEMBER OF:					LOCATION 																			
	ADJUSTABLE RECIRCULATING FITTINGS																								
	Fig. 6106T . . . THREADED INLET ONLY																								
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;">A SIZE</th> <th style="width: 10%;">MIN</th> <th style="width: 10%;">X</th> <th style="width: 10%;">MAX</th> <th style="width: 40%;">Free Area</th> </tr> </thead> <tbody> <tr> <td>0150(40),02(50),03(75)</td> <td>1(25)</td> <td>2(51)</td> <td></td> <td>5.6 SQ IN (36) SQ CM</td> </tr> </tbody> </table>										A SIZE	MIN	X	MAX	Free Area	0150(40),02(50),03(75)	1(25)	2(51)		5.6 SQ IN (36) SQ CM						
A SIZE	MIN	X	MAX	Free Area																					
0150(40),02(50),03(75)	1(25)	2(51)		5.6 SQ IN (36) SQ CM																					
REGULARLY FURNISHED: Duco Cast Iron Body with Secured Chrome Plated Bronze Face and Flow Regulating Device VARIATONS: Flashing Clamp -C Vandal Proof Screws -U OPTIONAL MATERIALS: Galvanized Cast Iron -G Nickel Bronze Face -NB Polished Bronze Face -PB																									
NOTE: This product does not conform to or meet the requirements of ASME Standard No. A112.19.8-2007, titled "Suction Fittings for Use in Swimming Pools, Wading Pools, Spas, and Hot Tubs." This product shall not be used in any installation in swimming pools, wading pools, spas, hot tubs as well as other aquatic facilities. Due to the potential endangerment from arduous and forceful suction, entrapment or entanglement regardless of whether it is hair, head, limbs or other body parts, this product is prohibited from installation in these applications.																									
NOTE: Dimensions shown in parentheses are in millimeters.																									
6106	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%; text-align: center;">F E D C</td> <td style="width: 10%;">7-20-23 1/5/09 12/17/08 12/08/08</td> <td style="width: 30%;">Removed Function Revised Function & Heading Revised Chart Revised Variations</td> <td style="width: 10%;">HS RN RN RN</td> <td style="width: 10%;">CL CL CL CL</td> <td style="width: 10%;">WEIGHT POUNDS</td> <td style="width: 10%;">VOLUME CUBIC FEET</td> <td style="width: 20%; text-align: center; font-size: 24px; font-weight: bold;">FIGURE NUMBER 6106</td> </tr> <tr> <td>REV.</td> <td>DATE</td> <td>DESCRIPTION</td> <td>BY</td> <td>CKD. BY</td> <td></td> <td></td> <td></td> </tr> </table>									F E D C	7-20-23 1/5/09 12/17/08 12/08/08	Removed Function Revised Function & Heading Revised Chart Revised Variations	HS RN RN RN	CL CL CL CL	WEIGHT POUNDS	VOLUME CUBIC FEET	FIGURE NUMBER 6106	REV.	DATE	DESCRIPTION	BY	CKD. BY			
	F E D C	7-20-23 1/5/09 12/17/08 12/08/08	Removed Function Revised Function & Heading Revised Chart Revised Variations	HS RN RN RN	CL CL CL CL	WEIGHT POUNDS	VOLUME CUBIC FEET	FIGURE NUMBER 6106																	
REV.	DATE	DESCRIPTION	BY	CKD. BY																					